



ADDENDUM #1

DATE: September 17, 2019

FROM: Jennifer Rogers, Superintendent of Parks- Trades
ARLINGTON HEIGHTS PARK DISTRICT

TO: PROSPECTIVE BIDDERS – Boiler Replacements Bid

SUBJECT: ADDENDUM #1 – Clarification for Bid Document

Addenda to Bid Document Specifications

1. Pg. 14 #11: The venting for the new high efficiency boilers:
Existing windows near to the boilers can be utilized as long as they are properly vented, secured, and sealed.
2. Pg. 14 #18: This is to verify the routing available for the wiring for the iVue controller:
The wiring can run from the southeast corner office on the second floor where the iVue main control is north through the second floor above the drop ceiling, to a closet in the northeast corner of the building. In this office closet, you can run wire down to the training room in the basement, then across into the boiler room through drop ceiling. All of this will be verified with the winning bidder before work is completed.

BIDDERS ARE REQUESTED TO SIGN THIS FORM AS A FORMAL RECEIPT OF THIS ADDENDUM AND TO RETURN IT WITH THE BID FORM.

SIGNED BY BIDDER _____