



### ADDENDUM #3

DATE: 4/29/2026  
FROM: Chance Andell  
Arlington Heights Park District  
TO: Prospective Bidders – Camelot Tennis Court Renovations  
SUBJECT: Addendum #3

#### **Addenda to Bid Document**

Sheet C-102 mentions that fence posts are to be driven. The project specifications call for concrete set on the fence posts.

Corner fence posts should be set in concrete and all intermediate fence posts should be driven to refusal.

Alternate 1 on the bid form calls for 12' Black Vinyl Coated Chain Link Fabric. The existing fence is 10' in height, please use 10' Black Vinyl Coated Chain Link Fabric for Alternate 1.

**BIDDERS ARE REQUESTED TO SIGN THIS FORM AS A FORMAL RECEIPT OF THIS ADDENDUM AND TO RETURN IT WITH THE BID FORM.**

SIGNED BY BIDDER \_\_\_\_\_